



- (3,853) active water meters. (971 of meters were installed before 1988.)
- ◉ (202) Sample sites for Lead and Copper Survey.

None of the sample sites contained lead in the service line or customer line.

Using a statistical approach in accordance with procedures established by the Kentucky Division of Water, Todd County Water District verified that 202 of 971 of randomly selected service lines installed before 1988 were not lead. Based on this information, we are 95% confident that fewer than 1% of the unknown service lines in our area are constructed of lead, therefore, we are going to classify all remaining unknown service lines as non-lead at this time.

We will continue to document service line materials in the future during routine operations throughout the system. If you would like Todd County Water District to physically inspect your line to verify the material, please contact us at 270-265-2229.